

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F4381

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

ARF-WL8-OH Wireless Multi-Sensor Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

ASI Oy Ltd
Laitaatsillantie 3
Savonlinna
57170
Finland

ASI Oy Ltd
Laitaatsillantie 3
Savonlinna
57170
Finland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors - Point detectors

EN 54-7:2018 - Smoke detectors - Point detectors

EN 54-25:2008 - Components using radio links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 21 May 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 21 May 2020

Date of Issue: 17 August 2023

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4381

ARF-WL8-OH Wireless Multi-Sensor Detector

Variants:

EK-WL8-OH – (EKHO Brand)
KM-WL8-OH – (K-Mesh Brand)

Notes:

1. Meets the requirements of EN 54-5 for the following settings:
 - Category A1R
2. Approved to EN54-7 at the following sensitivity settings:
 - High
 - Medium
 - Low
3. The device must be used with the following batteries only:
 - Primary – CR123A (3V)
 - Secondary – CR2032 (3V)



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 21 May 2020

Date of issue: 17 August 2023

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie