

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F4388

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### ARF-WL8-HS Wireless Category A1R Heat Detector with Type A Built-in Sounder

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

ASI Oy Ltd  
Laitaatsillantie 3  
Savonlinna  
57170  
Finland

and produced in the manufacturing plant(s):

ASI Oy Ltd  
Laitaatsillantie 3  
Savonlinna  
57170  
Finland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 – Sounders  
EN 54-5:2017 + A1:2018 - Heat detectors - Point detectors  
EN 54-25:2008 - Components using radio links

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 25 June 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Z Major, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 25 June 2020

Date of Issue: 3 November 2023

Issue number 04

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## APPENDIX to Certificate of constancy of performance: 2831-CPR-F4388

### ARF-WL8-HS Wireless Category A1R Heat Detector with Type A Built-in Sounder

#### Variants:

EK-WL8-HS – (EKHO Brand)  
KM-WL8-HS – (K-Mesh Brand)

#### Notes:

- Meets the requirements of EN 54-3:2001 for the following tones:
  - One tone Steady, 3500Hz (On)
  - One tone Meander, 3500Hz (1s On / 1s Off)
  - One tone Meander, 3500Hz (2s On / 2s Off)
  - Two tone, 3500Hz & 2150Hz (1s / 1s)
  - Two tone, 3500Hz & 2150Hz (0.4s / 0.4s)
  - One tone intermittent, 3500Hz (0.2s On / 1.3s Off)
  - ISO8201, 3500Hz (3\*0.5s / 1.5s Off)
  - One tone continuous, 1000Hz (Continuous tone)
  - One-tone intermittent, 1000Hz (1s On / 1s Off)
- The device must be used with the following batteries only:
  - Primary – CR123A (3V)
  - Secondary – CR123A (3V)



Z Major, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 25 June 2020

Date of issue: 3 November 2023

Issue number: 04

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)